

REQUEST FOR INFORMATION (RFI)

| | | |
|-------------------|--|---|
| PROJECT NUMBER: | 610A4-12-107 | Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner. |
| PROJECT TITLE: | Renovate First Floor East Wing Building 1 for PACT | |
| PROJECT LOCATION: | Department of Veterans Affairs N. Indiana Health Care System 2121 Lake Ave. Fort Wayne, IN 46805-5100 | |

| | | | |
|---------------|-----------------------------|-------------|----------------|
| SUBMITTED BY: | Michael Kinder & Sons, Inc. | City/State: | Fort Wayne, IN |
| PHONE NO.: | 260-744-4359 | | |

TO: Contract Specialist Richmond McCloud
Richmond.mccloud@va.gov

| | | |
|------------------|---------------|--|
| RFI NO.: 1 | DATE: 8/15/13 | REFERENCE: Drawing AD.101 Demolition Notes 1 |
| REPLY NEEDED BY: | | Spec. 02 82 11-2 Note #1 |

INFORMATION NEEDED:

Do all hard plaster ceilings demo on 1st floor in remodeled rooms?

REPLY:

Yes, all hard plaster ceilings are to be demolished in the 1st floor project area.

REPLY FROM:

DATE:

ATTACHMENTS:

COPY TO: