

REQUEST FOR INFORMATION (RFI)

PROJECT NUMBER:	610A4-12-107	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Renovate First Floor East Wing Building 1 for PACT	
PROJECT LOCATION:	Department of Veterans Affairs N. Indiana Health Care System 2121 Lake Ave. Fort Wayne, IN 46805-5100	

SUBMITTED BY:	Michael Kinder & Sons, Inc.	City/State:	Fort Wayne, IN
PHONE NO.:	260-744-4359		

TO: Contract Specialist Richmond McCloud
Richmond.mccloud@va.gov

RFI NO.: 3	DATE: 8/15/13	REFERENCE: Drawing AS501 Detail 1 &
REPLY NEEDED BY:		AS-102

INFORMATION NEEDED:

Detail 1/AS-501 shows 5/8" gypsum board. Drawing AS-102, floor plan note II calls for cement backer board and plaster. Which one is required?

REPLY:

Note 11 on AS-102 to read "INFILL VOIDS IN EXTERIOR WALL AFTER REMOVAL OF RADIATOR GRILLES (REF. MECH. DEMOLITION PLAN) WITH METAL STUDS AND 5/8" GYPSUM WALL BOARD FLUSH WITH EXISTING WALL. FOR PTAC OPENING INFILL – REF. DETAIL 1/AS-501."

REPLY FROM:	DATE:
ATTACHMENTS:	COPY TO: