

REQUEST FOR INFORMATION (RFI)
VA-251-12-B-0077

PROJECT NUMBER:	515-10-109	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	REPLACE HVAC		
PROJECT LOCATION:	Department of Veterans Affairs Battle Creek 5500 Armstrong Rd Battle Creek, MI 49037		
SUBMITTED BY:	Harry Armitage J&L Electric	City/State:	Battle Creek, MI
PHONE NO.:	269-962-0774 X116		

TO:

Richmond McCloud, Contract Specialist
Department of Veterans Affairs
Attn: 90NCO
2215 Fuller Rd.
Ann Arbor, MI 48105
richmond.mccloud@va.gov

RFI NO.:	DATE:8/12/2013	SPEC/DWG. REFERENCE: E103 & MH601
REPLY NEEDED BY:		

INFORMATION NEEDED:

Are there any more detailed plans showing power panel locations in building 82. Location of feed to new panel and VAV DDC Need to be determined.
Thanks

REPLY:

The following is our response to the electrical feed issue on Building 82.

“The contractor must install a new 300/3 CB in the existing Panel PD in the Basement. He must replace the existing feeder to Panel PA with a new feeder to be 4-350KCM, #4G, 3”C. Panel PA in the penthouse will be replace with a new panel fed by the new feeder. Determination of conduit routing is up to the contractor.”

REPLY FROM:	DATE:
ATTACHMENTS:	COPY TO: