

**R.F.I.**  
(REQUEST FOR INFORMATION)

<b>Project #:</b>	605-327	<b>RFI #:</b>	27
<b>Project Name:</b>	OP Pharmacy Building	<b>Date Requested:</b>	08/23/2013
<b>Solicitation No.:</b>	VA262-13-B-0591	<b>Reference:</b>	Electrical
<b>Drawing:</b>		<b>Specification Section:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED</b>			
(Please be specific.)			
Amendment 3 has huge electrical changes. Our electrical supplier cannot give us pricing on:			
<ul style="list-style-type: none"><li>• The added a padmount 12kv transformer (due to no specs).</li><li>• On revised sheet E 611 note 4 there is an existing 15KV gear line-up that we will have to add a breaker to but there is no info on the existing equipment. That 1 breaker could be \$25K-\$75K.</li><li>• The added UPS system (due to no specs).</li><li>•</li></ul>			
<b>OWNER RESPONSE</b>			
<ul style="list-style-type: none"><li>• Please see attached Pad mounted Medium Voltage Transformer Specs section 26 12 19</li><li>• Since the Unit Substation is under separate contract, please see VA Project Management, Project Engineer or COTR for equipment information.</li><li>• Please see attached UPS specs section</li></ul>			
<b>OWNER TRACKING No.:</b>		<b>AMEND No.:</b>	
VA Project Engineer/Manager: <i>Co Concar</i>		Date: 08/26/2013	