

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	605-327	RFI #:	29
Project Name:	OP Pharmacy Building	Date Requested:	8/26/13
Solicitation No.:	VA262-13-B-0591	Reference:	
Drawing:	E-611 (Amendment 03)	Specification Section:	None listed.

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

“Amendment 003” drawings reflect power source to come from existing 12KV Substation US-6A, Requiring a new 12KV MV Draw-out Breaker to be installed into existing.

Information Requested; Manufacture & Name Plate information from existing Substation US-6A.

OWNER RESPONSE

Unit Substation "US-6A" will be provided with the required circuit breaker for the Outpatient Pharmacy to use. A new circuit breaker will not be required.

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date: