

# R.F.I.

(REQUEST FOR INFORMATION)

<b>Project #:</b>	605-327	<b>RFI #:</b>	31
<b>Project Name:</b>	OP Pharmacy Building	<b>Date Requested:</b>	8/26/13
<b>Solicitation No.:</b>	VA262-13-B-0591	<b>Reference:</b>	
<b>Drawing:</b>	E-611 (Amendment 03)	<b>Specification Section:</b>	None listed.

## DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

“Amendment 003” drawings reflect power source to come from existing 12KV Substation US-6A, Requiring a new 12KV MV Draw-out Breaker to be installed into existing, to Feed new 750KVA pad Mount Transformer. Note 10 require new Utility Meter in the Pad Mounted Main Switch Board enclosure.

Information Requested; Clarification requested.

Equipment is already being metered upstream by utility Company @12KV.

Need to know what type of meter will actually be required since SCE utility will not provide a second Meter.

Need Specification Section for metering requirement on switchboard MSB.

## OWNER RESPONSE

SCE is providing metering one meter for the entire campus, the meter in MSB is for specific building usage only and is not an SCE meter.

**OWNER TRACKING No.:**

**AMEND No.:**

**VA Project Engineer/Manager:**

**Date: 08/26/13**